



Tom Barrett  
Mayor

Bevan K. Baker, FACHE  
Commissioner of Health

Joe'Mar Hooper, MPA  
Health Operations Administrator

[www.milwaukee.gov/health](http://www.milwaukee.gov/health)

Frank P. Zeidler Municipal Building, 841 North Broadway, 3rd Floor, Milwaukee, WI 53202-3653 phone (414) 286-3521 fax (414) 286-5990

## Routine Food

Institute of Technology & Academics, Inc.  
Institute of Technology & Academics (R)  
8940 N 85th St  
Milwaukee, WI

**9/15/2015**

The following list of violations of the Wisconsin Administrative Code as adopted by reference in the Milwaukee Code of Ordinances Chapter 68, and/or other City ordinance(s) must be corrected as soon as possible but not later than the date specified. A re-inspection fee may be assessed if the violation is not corrected by that date. An inspection fee may be charged for any repeat violations.

**Fee Amount:**  
**\$107.00**

### CDC Risk Code Factor Violation(s)

Code Number	Description of Violation	Correct By
CDC Risk Violation(s):	0	

### Good Retail Practice Violations(s)

Code Number	Description of Violation	Correct By
5-103.11	There is no hot water in the building. Provide both hot and cold water at all handsink. Repair plumbing. Provide an adequate water supply.	9/29/2015
5-202.11	In the girls bathroom the right handsink is missing the cold water faucet handle and on the left sink no water comes out of the hot faucet. Repair sinks to working order and maintain. Properly repair plumbing.	9/29/2015

**Good Practice Violation(s):** 2

**Total Violations:** 2

### **Notes:**

Food Safety Plan in order except log sheets for 2 milk coolers. Start and maintain all log sheets.

On 9/15/2015, I served these orders upon Institute of Technology & Academics, Inc. by leaving this report with

Inspector Signature (Inspector ID:84)

Operator Signature